

PAT Test

Wynd Cottage, 45 Cliff Street, Whitby. YO213DD

Inspector/tester: A. G. Bell

Date: 3/11/16

Test Equipment: UNI-T UT527

Location	Item	Visual	Fuse	Class	PAT
Dining room	TV	pass	3A	2	pass
	Iron	pass	13A	1	pass
	Dyson	pass	13A	2	pass
	Radio	pass	n/a	2	pass
	Charger 1	pass	n/a	2	pass
	Charger 2	pass	n/a	2	pass
Kitchen	Toaster	pass	13A	1	pass
	Slow cooker	pass	3A	1	pass
	Microwave	pass	13A	1	pass
	Fridge	pass	13A	1	pass
	Kettle	pass	13A	1	pass
	Dishwasher	pass	13A	1	pass
Living room	TV	pass	3A	2	pass
	Playstation	pass	5A	2	pass
	Lamp	pass	3A	2	pass
	Cordless vac	pass	n/a	2	pass
	5 way extension	surge	13A	n/a	n/A
	Corner lamp	pass	3A	1	pass
Bed 1	TV	pass	3A	2	pass
	Lamp 1	pass	3A	2	pass
	Lamp 2	pass	3A	2	pass
	4 way extension	pass	13A	n/a	pass
					pass
Bed 2	TV	pass	3A	2	pass
					pass
Bed 3	TV	pass	3A	2	pass
	Lamp 1	pass	3A	2	pass
	Lamp 2	pass	3A	2	pass
	Hair dryer	pass	13	2	pass
Wash house	Washer/dryer	pass	13A	1	pass
	Extension	pass	13A	n/a	pass

20/12/2016

20/12/2016